1

2

4

5

7

8

9

BILL NO. S-78-11-64

SPECIAL ORDINANCE NO. S- 250-7

AN ORDINANCE approving a blanket purchase order - City Utilities Purchase Order No. B-0339 for equipment for Water Maintenance and Service Department.

BE IT ORDAINED BY THE COMMON COUNCIL OF THE CITY OF FORT WAYNE. INDIANA:

SECTION 1. That the blanket purchase order - City Utilities Purchase Order No. B-0339, dated November 13, 1978, between the City of Fort Wayne, by and through the City Utilities Purchasing Agent and the Board of Public Works and Mueller Company, for:

> purchase of an estimated 150 fire hydrants (Mueller A-429) for the Water Maintenance and Service Department,

all as more particularly set forth in said purchase order, which is on file in the Office of the Department of Purchasing and is by reference incorporated herein and made a part hereof, be and the same is in all things ratified, confirmed and approved.

SECTION 2. That this Ordinance shall be effective upon passage and approval by the Mayor.

APPROVED AS TO FORM AND LEGALITY,

. Keatt the fi	irst time in iun and	on motion by	Burn	, secc	паеа Бу	
· Ott			the second time by			e
Committee on	Hey	- Cety Uti	Lety (and the City	Plan Commis	ssion for	
recommendation)	and Public Hearing	to be held a	fter due legal notice	, at the Cou	ncil Chamb	ers,
City-County Buil	ning, Fort Wayne,	Indiana, on _	, th	10		ay
of	, 19_	, at	o'clock M	.,E.S.T.		
DATE:	11-28-18		Charles U	1). Wester	man /s	e
			CITY CLER			
Read the th	1 0 .		- Bu			_,
seconded by	U. Dehm	idt, and	duly adopted, plac	ed on its pa	ssage.	
PASSED (LOST)	by the following v	ote:				
	AYES	NAYS	ABSTAINED	ABSENT	TO-WIT:	
TOTAL VOTES	9	0				
BURNS	+					
HINGA	X					
HUNTER						
MOSES						
NUCKOLS	X					
SCHMIDT, D.	X					
SCHMIDT, V.	$\overline{}$				_	
STIER	X					
TALARICO	X					
	12-12-78		Much	10./11	etura a	M.
			CITY CLERI	ζ		
Passed and	adopted by the Con	mon Council	of the City of Fort V	Vayne, India	nna, as	
(ZONIN <del>G MAP) (</del>	ENERAL) (ANNEX		ECIAL) (APPROPR		_	. (>
(RESOLUTION) N	250-78	on the	12th day	of Decou	bed .	19
11.11	11/1		Samuel	1 Tal	arical	
CITY CLERI	h. Malismo	w	PRESIDING	/		-
Presented b	y me to the Mayor o	of the City of	Fort Wayne, Indians	a, on the	13-0h	
day of Doce	udu , 19 <u>28,</u> at	the hour of_	11:45 o'clock	M.,E.S.	т.	
			CITY CLERK	fle h	lectur	we
Approved a	nd signed by me thi	is 20+	L_day of	ecembe	<i>v</i> .	1978
	3 . o'cloc		P. M.E.S.		0	
			Kobate	Jamel	rong	
			/ (		7	

S-78-11-64 Bill No. REPORT OF THE COMMITTEE ON CITY UTILITIES We, your Committee on \_\_\_\_\_ City Utilities \_\_\_\_\_ to whom was referred an Ordinance approving a blanket purchase order - City Utilities Purchase Order No. B-0339 for equipment for Water Maintenance and Service Department have had said Ordinance under consideration and beg leave to report back to the Common Council that said Ordinance A PASS. PAUL M. BURNS - CHAIRMAN JAMES S. STIER - VICE CHAIRMAN VIVIAN G. SCHMIDT WINFIELD C. MOSES, JR. FREDRICK R. HUNTER

MUELLER CO. Attn. Ar. Don Foland Chief Water Edward Herm Wiehaus OCT 2.0 1978 DATE 10-19-1978 FORT WAYNE WATER UTILITY ENGINEERING DEPT. This will confirm our conversation of yesterday regarding Mueller Fire Hydrants. As I said yesterday the A-419 Hydrant is being phased out of production. Parts will still be available for this hydrant of course for years. In checking past records, there are about 20-25 of this two hydrant in your water system now.

Upon learning of this A-419 situation, some two years ago, Dave Resler and I approched you indicating this phase out of the A-419. We asked that you consider the A-414 Mueller Hydrant in place of the A-419, and went over a blue print of the A-414 with you. You indicated that this A-414 would meet with your approval and for the past two years we have been selling this Hydrant in the Ft. Wayne market. We estimate that you presently have 125-150 of the A-414 in your water system presently.

You will recall that Forrest Baum and I informed you recently that a change was in the making on the A-414. Mueller C. engineers are not confident in the franchle bolt type

traffic model construction in the A-414. They feel

REPLY TO there are just to many

City of Ft. wayne

Ft. Wayne, Ind.

Fire Hydrants

UBJECT

Don:

DATE

potantial problems with breakable bolt type traffic model hydrants. So a change will be made on the A-414 to use the tried and tested Mueller Traffic Flange type construction, a much more reliable system. In making the change, the runber of the Hydrant also changed, to a A-429, Centurion type hydrant. Therefore the confusion in runber used on the recent Hydrant. bid to the City of Ft. Wayne. There will be interchangeability of parts, except for the traffic flage system of course.

Hope this helps to the slove the Mueller number confusion. If you have any question, nlease advise. I will also order out some parts for the A-419, for the few you have in your system, and supply these parts on a no charge basis.

Regards

leruar

P. D. Please pardon this stationary, but I wanted to get this letter to you quickly. Also LISIGNED

## Memorandum

To H. P. Wehrenberg, Board of Works	Date November 13, 1978
From Ruth Winget, Purchasing Department	•
Subject Bid Reference #490, Fire Hydrants	·

CORIES TO:

E. A. Stanczak Jr. S. I. Miller

Herewith are bid documents (Bid #490) relating to Purchase Order Number B-0339 which is prepared favoring Mueller Company for One Hundred and Fifty (150) Fire Hydrants for Water Maintenance & Service Department.

Fourteen (14) vendors were invited to bid. Five (5) bids were received with Mueller Company quoting the lowest at \$340.70/ea. TOTAL APPROXIMATE VALUE: \$51,105.00.

Attached are the following documents in support of the recommendation for acceptance of Mueller Company bid.

- 1. Copy of Tabulation Sheet.
- Purchase Order Number B-0339.
- Copy of all vendor's bids.
- 4. Copy of Bid Mailing List.
- 5. Copy of S. L. Miller's memorandum.
- 6. Copy of D. L. Foland's memorandum. It is urged that in referring this bid to the City Council for enactment of an ordinance, that all of the attached items, together with this memorandum (or copies), be included with the proposed ordinance.

Please make sure that no confirming Purchase Order Number is given to Mueller Company until evidence of Council approval is furnished to the Purchasing Department.

B. a. Winger

Approved: Of Buzlan R. F. Bugher

Bid Tabulation #490 FIRE HYDRANTS Water Maint, & Service Dept. October 5, 1978 at 11:00 A.M.	Estimated 150 Fire Hydrants		
VENDORS  Mueller Ev.  Afd. O.K. Afd attached  270-10 Tet 30	Mueller 340,70 B-0339 15-90 days A.R.O.	add of deduct	20% p
Water Works afa on file konl	15-90 days A.R.O. Waterous 382.00.	add 4 dedust	1090 p.
afd. O.K. a/a on file	Henredy 370,83	add + diduct	10% p.
andrican Darling y Value atd. C.K. a/d none	american Starling	and Adelust	10% pi
V. H. Myere	no Bid		
Sign of Supply after on file	Muller 449.00	add & declus	10% p.
		-	
	,		
			:

## CITY OF FORT WAYNE

## CITY UTILITIES

DEPARTMENT OF PURCHASES
ROOM 950 CITY—COUNTY BUILDING
NUMBER ONE EAST MAIN STREET
FORT WAYNE, INDIANA 46802

Mueller Company 1401 Mueller Avenue Chattanooga, Tennessee ORIGINAL B-0339

PURCHASE ORDER NO.

This number must appear on each package, packing slip, invoice, bill of lading, express ryceipt and correspondence.

November 13, 1978

SHIP TO --

Water Maintenance & Service Dept. 415 East Wallace Street Fort Wayne, Indiana 46803 MAIL ALL INVOICES TO -

GENERAL ACCOUNTING
4th FLOOR CITY - COUNTY BUILDING
NUMBER ONE EAST MAIN STREET
FORT WAYNE, INDIANA 46802

.INVOICE IN DUPLICATE, INCLUDING
CERTIFICATION AS REQUIRED BY
INDIANA STATE BOARD OF ACCOUNTS

PECEIVED	QUANTITY DRDERED	DESCRIPTION	ACC'T, OR W.O. NO.	UNIT PRICE	TOTAL
	Est. Qty.	BLANKET PURCHASE ORDER FOR 1979 FOR FIR HYDRANTS	E		
	150	Fire Hydrants (Mueller A-429)		340,70/ea	
	150	Add or deduct for each 6" variation in		340.70766	
		trench depth \$7.20 Discount from inclu	déd	ESTIMATED	\$51,105 0
		List 20%	×	-	7
			. 61.	/ > 4	
		i die des	1 1 2	. 0. /	
			19/10	6-00	~
		.9		Francisco .	
		Requirements will be released on departs Purchase Orders against this blanket or			
		as required by the using department.	1		n 3 Y
	-		ATTE	NTIO	N!
		SUBJECT TO COUNCILMANIC APPROVAL	Send all invoices	to Genera	Ascounting
		Per Bid Ref. #490	4th Floor, C	Main Sc	5.5g.
		2% 10 Net 30	Fort Wayne		16802
		F.O.B. Delivered	Show P. O. Nur	ber on P	acking Slip
	ŀ	Delivery: 75-90 days A.R.O. FIRM PRICE	and Invoice.		
		RW/pl #5011			

NOTE: TERMS OF PAYMENT MUST BE SHOWN ON FACE OF INVOICE, OTHERWISE A 2% CASH DISCOUNT WILL BE TAKEN

City Utilities /40/ Mueller and RICHASE REQUISITION Chattarooga Jens

n or perore	415 E. Wallace	O. No.	B-033
QUANTITY	DESCRIPTION	DIST. NO.	DEPARTMEN ESTIMATED C
	Rock the Blacket Order for		
	1979 for Sine hydrenter		
Oty.			
150	Fire Hydrants (Bulley A-429)	340 70/	
	add ordeduct for each 6" &		
	variation in trench depth \$7,20		
	Discourt from included parts		
	List 20%		
	7.0.B. A	900	
	Per Bid Bol # 490 Delivery		1
REMARKS:	2%-10 nel 30 Fin Pr		0
			Ru
tes			7
	the Marates	educi-	* Serve
un-	ent will be		
care	on departmental Norm V	Sonwa	)*
	- Bet orderas		

## FORM OPER 5-48

# CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES 46802 Number One Main St., Ft. Wayne, Ind.
INVITATION

Quosations, subject to the conditions on the reverse hereof, are requested on the following list of materials, supplies, equipment or perfores, for the department as manufaced, with delivery to destination as shown below. Constitute shall include all charges for delivery, making, with Antires your repay as December below.

\*Mall all replies and R. F. Bugher 423-7037 DEPARTMENT OF PURCHASES

Room 470, Number One Main St., Ft. Wayne, Ind. REQUIRED FOR DELIVERY TO:

Department Water Maintenance & Service Dept. or Division 415 East Wallace Street

Fund Appropriation No.

Data wanted

Ref. No. .

· 1 of 5

490

Data August 29, 1978

Fort Wavne, Indiana 46803 Address ... RETURN ORIGINAL TO THE CITY-RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Thursday, October 5, 1978 at 11:00 A.M. Time of Bids

TAINS! THE CITY IS WINGT FROM YIDIRAL RICHE AND INDIANA STATE SALIS TAX. THE CITY'S INDIANA SALIS TAX EXPECTION CONTINUATE NUMBER IS NO, MADE PRICES EXCULORYD INDIANA SALIS TAX EXPECTION.

TAX EXEMPT (Unless otherwise indicated)								
Cuantity	Unit	Mahariala, Sapplies, Laulyment or Services	Unit Price	Americal				
		FIRE HYDRANTS - 1979 Requirements						
		Estimated usage for January 1, 1979 thru December 31, 1979						
		The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.		:				
		We require a guaranteed firm price for the period January 1, 197 thru December 31, 1979 and delivery to our yard within 30 days notification of release. This will not be a one time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.	€					
		Your parts list, with discounts, must accompany your bid.  A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approvat, and the hydrants are to be delivered only upon issuance of departmental purchase orders.						
	7	Affirmative Action On File: Attached:						
Bid Bond :		NO YES NO TES Performance Bond VX D						
Teçma_/		See lastraction than No. 16 on reverse tide bered.  cash discount if paid withindays from delivery and acceptance of goods or com-	pletion c	d services.				
-		PROPOSAL OR BID						

In compliance with the shows invitation for bild and relief to all conditions thereof, the understand offers and acrees, if this bid he accorded within a reasonable time from these of density, to formall any or sired the items or reader such sarrious upon which prices are quoted, in accordance with the predictances appring and at the rose and format. Delivery of any or all of the items or completion of services indicated shall be made within days from receipt of order As delivery may be a deciding factor in the award of an order, it is important that hidden furnish the information requested shows high his allemidation. IMPORTANT FF

$\neg$	Water Works Supplies Inc
	For But Kallmayer True Office Mgr.
	P.D. BOX 872 305 Missouri Ave.
	as Jeffersenville IN 47130 on 10-4-

#### FIRE HYDRANT SPECIFICATIONS Section D - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Water Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with Section λ-4a of these standards, shall open by turning left (counter clockwise), shall have a minimum valve opening of five (5) inches, shall be equipped with 0-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having Wational Standard Fire Hose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively, and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length to as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved eguals, are the only fire hydrants which will be accepted for use in connection with water main installations:

BRAND NAME:	CATALOG NO.
Kennedy	K-10B
American - Darling	B-62B
Traverse City	H-1-M
Waterous	WB-67
Mueller	A-419

Estimated Usage - 150



# CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES Number One Main St., Ft. Wayne, ind. 46802

INVITATION

Cocations, subject to the conditions on the reverse haroof, for replaced on the following list of materials, supplies, equipment or perfore, for the department as mantioned, with delivery to destination as shown below. Cocations shall include all charges for delivery, making, we. Accuracy your reply as increased severe.

\* Wall all moles and R. F. Bugher 423-7037 DEPARTMENT OF PURCHASES Room 470, Number One Main St., Ft. Wayne, Ind.

REQUIRED FOR DELIVERY TO:

Department Water Maintenance & Service Dept. or Division 415 Fast Wallace Street

Fort Wayne, Indiana 46803 Address \_

RETURN ORIGINAL TO THE CITY-RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Thursday, October 5, 1978 at 11:00 A.M. Time of Bids

TAXES, THE CITY IS KINGT FROM TIDERAL EXCESS AND RIDIANA STATE SALES TAX. THE CITYS INDIANA SALES TAX EXCEPTION
CONTINUENTS NINGERS IS NO. 1868, PRICES SHOULD NOT INCLUDE THESE TAXES, See "Insuranteens to Bilders" No. 10 on present bernef for deadles.

matte	Unit	Materials, Supplies, Equipment or Services	Pries	Total American
		FIRE HYDRANTS - 1979 Requirement's		
		Estimated usage for January 1, 1979 thru December 31, 1979		
		The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.		:
*		We require a guaranteed firm price for the period January 1, 1975 thru December 31, 1979 and delivery to our yard within 30 days notification of release. This will not be a one time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.		
		Your parts list, with discounts, must accompany your bid.		
		A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuence of departmental purchase orders.		
		Affirmative Action On File: X Attached:		
	.;			

	require			Performance			
				ion item No. 18 on reverse			
Tarr			of neid within 10				

PROPOSAL OR BID

to considered with the therefore for this led makes to all conditions to the control of the cont As delivery may be a deciding factor in the award of an order, it is important that bidders farmin the information requested above. IMPORTANT IS

Elgn Eleres				THC.
Kennedy Valve/Division	of	ITT	Gri	nnell
Anthony C. DeSocio, Si	(X)	74.	ssis	tant

Page 1 of 5

490

Data August 29, 1978

Ret. No.

Data wanted \_

Appropriation No.

Secretary 1021 East Water Street

Elmira, New York 14902 9/26/78

# FIRE HYDRANT SPECIFICATIONS Section D - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Water Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with section Λ-4a of these standards; shall open by turning left (counter clockwise); shall have a minimum valve opening of five (5) inches, shall be equipped with 0-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Nose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively, and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

mach fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

Kennedy	K-10B					
American - Darling	B-62B					
Traverse City	H-1-M					
Waterous	WB-67					
Mueller	A-419					
	*					
Estimated Usage - 150						
Hydrant Traffic Type 5' 6" Bur	ry \$ 370.83					
Add or Deduct for each 6" variation in trench depth\$ 8.10						
Percentage of discount from included parts list						

CATALOG NO.

BRAND NAME:

See Drawing D-80341-FWI attached.

46802

Page 1 of 5

490

Data August 29, 1978

Per. No. -

Data wanted

Appropriation No.

Fund

FORM DP23 5-68

0

## CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES

46802 Number One Main St., Ft. Wayne, Ind. INVITATION

Consistent subject to the conditions on the reverse bersel, are requested on the following list of speciations, mixed to the condition on the inverse harred, are represed on the following list of materials, arrive, extremes to extreme, for the optimizant as parameters, the delivery to desiration at above below. Considers shall include all pharms for delivery, machine, eq. Another your copy as increased to the contraction of the con

R. F. Bugher 423-7037 DEPARTMENT OF PURCHASES but odlers ile licks

Room 470, Number One Main St., Ft. Wayne, Ind. REQUIRED FOR DELIVERY TO:

Department Water Maintenance & Service Dept. or Division

415 Fast Wallace Street

Fort Wayne, Indiana 46803 Address \_\_ RETURN ORIGINAL TO THE CITY-RETAIN DUPLICATE COPY FOR YOUR FILE

Thursday, October 5, 1978 at 11:00 A.M. Closing

Time of Bids TARISH THE COT IS NUMBER OF YEAR PRICES EQUID NOT INCLUDE THERE TAXING SALES TAX THE COURT NOW IN CONTROL FROM THE CONTROL OF PROTECULE NOW HAVE BEEN AND ASSESSED TO A PROTECULAR NOW HAVE BEEN ASSESSED. TAX EXEMPT (Unless otherwise indicated)

eastly	Unia	Materials, Supplies, Essipment or Sorriese	. Price	Assertat
	J	FIRE HYDRANTS - 1979 Requirements Estimated usage for January 1, 1979 thru December 31, 1979		
		The enclosed Non–Collusion Affidavit must be properly executed and returned as part of your bid.		:
		We require a guaranteed firm price for the period January 1, 197 thru December 31, 1979 and delivery to our yard within 30 days notification of release. This will not be a one time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.	9	•
		Your parts list, with discounts, must accompany your bid.  A Blanket Purchase Order will be issued to the successful		
	- 0	company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuance of departmental purchase orders.		
		Affirmative Action On File: Attached: X	-	
			1 1	7
Bid Bond	required	NO YES Performance Bond CR C C See Ingerestors two No. 15 on premier title bereck		

Bid Bond	l required	Ç				a Item No. 16			- 1	-			
Tarma	2 ~	cash	discount	L paid withi	30	days from	delivery	r and a	cceptan	to 50	300d3 03	completion	of service
764													
					प्रव	OPOSAL.	OR BIL	D					

In compliance with the above investigate for bids and milect to all confidence across, the understand offers and agrees, if this bid he necessed writing a reasonable tender of the confidence across, the understand offers and agrees, the understand of the confidence across the confidence across and the Goddingson across and the confidence across across and the confidence across and the confidence across and the confidence across and the confidence across across and the confidence across and the confidence across across across and the confidence across across across across a confidence across Delivery of any or all of the items or completion of services indicated shall be made within days from receipt of order As delivery may be a deciding factor to the award of an order, it is important that Melon-formial the information respected above. DEPORTANT 157

MUELLER CO.	`	
Kacal E. Akcitis	Sa var	les Serv
1401 Mueller		Manager
Chattanooga,	TN	9/27

Fire Wares

# FIRE HYDRANT SPECIFICATIONS Section D - Fire Hydrants (Mains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Nater Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with Section A-4a of these standards; shall open by turning left (counter clockwise), shall have a minimum valve opening of five (5) inches; shall be equipped with 0-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Hose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively; and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

 BRAND NAME:
 CATALCG NO.

 Kennedy
 K-10B

 American - Darling
 B-62B

 Traverse City
 H-1-M

 Waterous
 WB-67

 Mueller
 A-429

## Estimated Usage - 150

Hydrant Traffic Type 5' 6" Bury	\$_	340.70
Add or Deduct for each 6" variation in trench depth	\$_	7.20
Percentage of discount from included parts list*		

Shipment of hydrants 75-90 days after receipt of purchase order.

Ref. No.

Data wanted

Appropriation No.

Data

Fund

· 1 of...

490

August 29

OF FORT

DEPARTMENT OF PURCHASES

Number One Main St., Ft. Wayne, Ind. INVITATION

Constitute, subject to the conditions on the reverse hereof, are requested on the following list of materials, supplies, engineess or sections, for the department as insufficient with delivery to destination as shown below. (Spotstions thall Include all charges for delivery, realities, sec. Access your roops as Decession Secret.)

\*Mall all replies and R. F. Bugher 423-7037 DEPARTMENT OF PURCHASES

Room 470, Number One Main St., Ft. Wayne, Ind.

REQUIRED FOR DELIVERY TO:

Department or Division. Water Maintenance & Service Dept 415 East Wallace Street

Fort Wayne, Indiana 46803 Address -

RETURN ORIGINAL TO THE CITY-RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Thursday, October 5, 1978 at 11:00 A.M. Time of Bids

TANES, THE CITY IS YIMAT FROM FEDERAL RIGHE AND INDIANA STATE SALES TAL THE CITY'S INDIANA SALES TAL MINEPTION CHRISTICATE NUMBER IS NO, 1981, PRICES SHOULD NOT INCLUDE THERE TAIRS, See "Instructions to Bilder" No, 10 on inverse berned for details.

46802

Quantity	Units	Materials, Supplies, Zanipment or Services	Price	Zacsi Amerai
		FIRE HYDRANTS - 1979 Requirement's		
		Estimated usage for January 1, 1979 thru December 31, 1979		
		The enclosed Non–Collusion Affidavit must be properly executed and returned as part of your bid.		·
		We require a guaranteed firm price for the period January 1, 197 thru December 31, 1979 and delivery to our yard within 30 days notification of release. This will not be a one time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.	9	•
		Your parts list, with discounts, must accompany your bid.		
		A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approvat, and the hydrants are to be delivered only upon issuance of departmental purchase orders.		
		Affirmative Action On File:Attached:		
	17	Sent Under Seperate cover XX		

days from delivery and acceptance of goods or completion of services. % cash discount if paid within\_ PROPOSAL OR BID

In compliance with the above invitation for this and miniest to all conditions thereof, the uncordinate drive and agrees, if this hid he accorded within a reaccomaintee from state of closure, to invitate any or sired the items or render such services upon which prices are opposed, in accordance with the specifications amounts and the pre-discussions amounts are not as a constant of the pre-discussions amounts and the pre-discussions amounts are not as a constant of the pre-discussions amounts are not as a constant of the pre-discussions amounts are not as a constant of the pre-discussions amounts are not as a constant of the pre-discussions are not as a constant of the

Delivery of any or all of the items or completion of services indicated shall be made within. days from receipt of order". As delivery may be a deciding farmer in the award of an order, it is important that hidden farming the information reported above. IMPORTANT 137

	E.gra	Hares	AMERICAL	1-DARI	LING .	VALVE
			American			
*******	77	7	I a Managed Com	nany (	112 10	ner

Brt Potton Service Rep. P.O. Box 2727

Birmingham, Al.

9-21-78

BRAND NAME:	CATALOG NO.
Kennedy	K-10B
American - Darling	B-62B
Traverse City	H-1-M
Waterous	WB67
Mueller	A-419

## Estimated Usage - 150

Hydrant Traffic Type 5' 6" Bury	\$_	350.00	
Add or Deduct for each 6" variation in trench depth	\$_	6.35	
Percentage of discount from included parts list	š.	10%	

# CITY OF FORT WAYNE

DEPARTMENT OF PURCHASES

Number One Main St., Ft. Wayne, Ind.
INVITATION

Containes, subject to the conditions on the reverse hereof, are requised on the following list of materials, supplies, equipment or services, for the department as mantioned, with delivery to destination as above below. Containes shall include all charges for delivery, making, see, Addisses your regiv as presented sometimes.

Noom 470, Number One Main St., Ft. Wayne, Ind. 46802

REQUIRED FOR DELIVERY TO:

Department or Division Water Maintenance & Service Dept

415 East Wallace Street
Address Fort Wayne, Indiana 46803

RETURN ORIGINAL TO THE CITY -- RETAIN DUPLICATE COPY FOR YOUR FILE

Closing Thursday, October 5, 1978 at 11:00 A.M.

TAXES, THE CITY IS RELIGIT FROM FIDERAL FIGURES AND DIDLAN, STATE SALES TAX. THE CITY'S DIDLANG SALES TAX PROPERTY OF CHART NUMBER IN NO. 10 on France Law for Control France Falls, See Transactions to Religion? No. 10 on France Law for Control Falls.

TAX EXEMPT (Unless otherwise indicated)

Quantity	Unit	Materials, Supplies, Equipment or Services	Price	Tacri Tacri
		FIRE HYDRANTS - 1979 Requirements		
		Estimated usage for January 1, 1979 thru December 31, 1979		
		The enclosed Non-Collusion Affidavit must be properly executed and returned as part of your bid.		:
		We require a guaranteed firm price for the period January 1, 197 thru December 31, 1979 and delivery to our yard within 30 days notification of release. This will not be a one time purchase. It is anticipated that release quantities will be 25 to 30 hydrants per release.	9	•
		Your parts list, with discounts, must accompany your bid.		
		A Blanket Purchase Order will be issued to the successful company, after necessary Councilmanic Approval, and the hydrants are to be delivered only upon issuance of departmental purchase orders.		
		Affirmative Action On File: Attached:		
Bid Bond re	quired			
Teçma	%	See lastrocton from No. 1s on reverse able bared."  cash discount if paid withindays from delivery and acceptance of goods or com	pletion o	i services.

PROPOSAL OR BID

To compliance with the above invention for this and subset to all considerable forties and agrees, if this bid he accorded within a reasonable for the control and the contro

BIDE + SUPPLY	
The Select The BREAK	mesil
P. O. 769	
JEFEERSON NUILLE IN 9	125/2

Page 1 of 5

490

Data August 29, 1978

Ref. No. \_

Data wanted

Appropriation No. -

Fund

# FIRE HYDRANT SPECIFICATIONS Section D - Fire Hydrants (Hains)

Fire hydrants used in the construction of water mains shall be of the traffic type and shall be made in accordance with the latest revisions of the American Nater Works Association Standards, designation C502; shall have a six (6) inch mechanical joint bell inlet at the base and all jointing accessories in accordance with section A-4a of these standards, shall open by turning left (counter clockwise), shall have a minimum valve opening of five (5) inches, shall be equipped with 0-ring packing, one and one-half (1-1/2) inch pentagon operating nut, one four and one-half (4-1/2) inch pumper and two (2) two and one-half (2-1/2) inch hose connections, all on the plane, and having National Standard Fire Nose threads of four (4) threads and seven and one-half (7-1/2) threads per inch, respectively, and a ground line flange and shall be painted Federal Yellow.

The fire hydrant barrels shall be of sufficient length so as to connect with the hydrant leg, attached to the water main, and so the ground line flange is not less than two (2) inches or more than six (6) inches above the finished grade of the adjacent area.

Each fire hydrant shall be installed with a six (6) inch mechanical joint valve between it and the main to which it is connected. There shall be a twenty four (24) inch nipple of six (6) inch pipe between the valve and the hydrant. The following fire hydrants, or approved equals, are the only fire hydrants which will be accepted for use in connection with water main installations:

9

BRAND NAME:	CATALOG NO.
Kennedy	K-10B
American - Darling	B-62B
Traverse City	H-1-M
Waterous	WB-67
Mueller	A-419

Estimated Usage - 150

### RECORDS OF SIDS ISSUED TO BIDDERS

BID NO. 490

ITEL: Fire Hydrants

DEPARTMENT: W.M. & S.

OPEN DATE: 10/5 TIME: 11:00

VENDOR NAME & ADDRESS	DATE - N	AME BIO	PICKED U	PCA	RDS MAILED	BID MAILED	RETURNEL .
Kennedy Valve						9-14-78	9-28-78
Traverse City Iron Works	* .			:	•	9-14-78	
Waterous Mfg. Company	7	*				9-14-78	-
Water Works Suppliers						9-14-78	10/5/28
Clow Corporation						9-14-78	
Tri~State Plumbing				Š	9-13-78		
American Cast Iron Pipe					. •	9-14-78	9-28-78
Dresser Mfg. Div.						9-14-78	
Midwest Utility Supply						9-14-78	-
Sidenor Supply of Indiana				the second second second second		9-14-78	
						,	

## RECORDS OF BIDS ISSUED TO BIDDERS

BID NO. 490  ITSH: Fire Hydrants  DEPARTMENT: W.M. & S.  OPEN DATE: 10/5 TIME: 1	1:00_			
VENDOR NAME & ADDRESS	DATE - NAME BID PICKED UP	CARDS MAILED	BID MAILED	RETURNE
Treaty Company	9-25-78 Bernie McCormick	9 <b>~1</b> 3~78		
V. R. Myers	9–19–78 Bob Franke			10/4/7
Pipe & Supply			9/19/78	10-4-7
Mueller Company			9-20-78	10-5-7.
		·		
		-		
			3	

### Memorandum

To Mr. Dick Bugher - Purchasing Department, City Date October 6, 1978

From Sheridan L. Miller-Superintendent, Water Maintenance & Service Dept.

Subject Bid Tabulations

COPIES TO:

Reference Bid #489 Tabulation for copper water pipe opened October 5, 1978, at 10:30 A.M., I would like to request that National Mill receive this bid. National Mill submitted the low bid, and their material is acceptable.

Reference Bid #488 Tabulation for cast iron fittings opened October 4, 1978, at 11:00 A.M., Items #1 and #2, I would like to request that the bid be awarded to V. R. Myers based on low bid and acceptable material.

Reference Bid #487 Tabulation for bronze fittings opened October 4, 1978, at 10:30 A.M., seven (7) companies submitted bids, and three (3) companies were discarded because of past experience of inferior materials. I would like to request that Items #1, #2, #3 and #4 be awarded to Ford Meter Box Company based on price and acceptable material. I would also like to request that Items #5 and #6 be awarded to Central Supply based on price and acceptable material.

Reference Bid \$490 Tabulation for fire hydrants opened October 5, 1978, at 11:00 A.M., I would like to request that this bid be awarded to the Mueller Company based on price.

Please note that on Bid #488 Tabulation for cast iron fittings, Items #3, #4, #5 and #6 and #7 will be shipped in by two (2) companies that bid on same. It is unknown at this time whether their material is acceptable. I will follow later with a reply on these particular items.

Sheridan L. Miller - Superintendent
Water Maintenance & Service Department
City Utilities

SLM/dm

## Memorandum

То	Richard Bugher, Director of Purchasing Date 11/13/78	
From	D. L. Foland, Water Engineering Department	
	AMARD OF CONTRACT FOR DURCHASE OF FIRE HADDANIE	

COPIES TO:

Subject

Lloyd Miller

Your verbal request for my review of the model fire hydrants, offered in the recent bid by the Mueller Company, as compared to the approved model in our material standards, has been evaluated and discussed with their area representative, Mr. Herman Neihaus. As a result, Hr. Neihaus has provided related information, a copy of which is attached.

Our findings are that the Model A-419, contained in our material standards, is a discontinued item and we have approximately 20-25 in our system. As a result, Mr. Neihaus and his supervisor, Mr. Resler, discussed the matter with me sometime ago and their Model A-414 was considered for approval and has been supplied in the past, although not formally approved in writing.

We also find that Model A-429 is identical to Model A-414, except its break-away feature is of an improved type and is, therefore, more desirable...all of the internal parts being interchangeable. We currently have approximately 125-150 of the A-414 models in our system. Incidentally, the basic design of the A-414 and A-429 are similar to the A-419, the difference being that the A-419 was of a modern style which did not gain acceptance and was, therefore, discontinued.

Based upon the above data, I recommend that we accept the bid of Mueller and award them contact to supply the quantity of fire hydrants bid, the model to be delivered being A-429.

As previously discussed, Lloyd Miller and I and representatives of our staff will be making a critical review of all materials, both for construction and maintenance purposes. We hope to have this review finalized and new specifications prepared for all types of water utility materials by the time the next bids are needed.

D. L. Foland, P.E. Chief Water Engineer

DLF/rcw Attachment TG. SOUND IN SOUND IN

TILE OF ORDINANCE CITY UTILITIES PURCHASE ORDER NO. B-0339 - MUELLER COMPANY DEPARTMENT REQUESTING ORDINANCE BOARD OF PUBLIC WORKS SYNOPSIS OF ORDINANCE BLANKET CITY UTILITIES PURCHASE ORDER NO. B-0339 TO MUELLER COMPANY FOR THE PURCHASE OF AN ESTIMATED 150 FIRE HYDRANTS (MUELLER A-429) FOR THE WATER MAINTENANCE AND SERVICE DEPARTMENT. (MEMORANDUM AND PURCHASE ORDER ATTACHED) THIS WAS THE LOWEST OF FIVE BIDS SUBMITTED EFFECT OF PASSAGE ACQUISITION OF FIRE HYDRANTS FOR CONSTRUCTION AND MAINTENANCE PURPOSES EFFECT OF NON-PASSAGE SELF-EXPLANATORY MONEY INVOLVED (DIRECT COSTS, EXPENDITURES, SAVINGS) FROM WATER UTILITY.

ESTIMATED \$51,105.00

ASSIGNED TO COMMITTEE